





NOTES:

1. Sidewalks shall be 4 inches thick, except that they shall be $5-\frac{1}{2}$ inches thick at curb cuts and curb ramps and where adjacent to rolled curbs.

P:\Engr & CAD\STANDARD DWGS - ALL YEARS\Std Dwgs 2014\Driveway Crossings Alternatives 8C.dwg

DRIVEWAY CROSSINGS - C

JOGGED SIDEWALK

PAGE NO:

80

CITY OF PULLMAN ENGINEERING DIVISION

ADOPTED: 12-09-2014